

**ADDENDUM NO. 2**  
**February 24, 2010**

**NOTTAWASEPPI HURON BAND OF THE POTAWATOMI**

***CONTRACT A - GENERATORS***

Addendum No. 2 to the plans and specifications for the Nottawaseppi Huron Band of the Potawatomi Contract A - Generators as prepared by Wightman & Associates, Inc., dated January, 2010.

This Addendum No. 2 supplements and modifies the Contract Documents relating to the above referenced project. This Addendum shall be deemed a part of the Contract Documents, and to the extent that the provisions of the other Contract Documents are in conflict herewith, this Addendum shall control.

1. Load Bank shall not be a permanent installation as called out for in the specifications. Contractor shall provide a portable load bank for initial startup and provide two (2) hour test.

The CONTRACTOR hereby acknowledges receipt of this Addendum No. 2 and shall include a signed copy with his bid.

Contractor: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

Nottawaseppi Huron Band of the Potawatomi  
CONTRACT A - EMERGENCY GENERATORS