

**ADDENDUM NO. 1**

**CITY OF BRIDGMAN**  
**WATER SYSTEM IMPROVEMENTS PROJECT**

**CONTRACT A – WATER MAIN AND APPURTENANCES**  
**CONTRACT B – WATER INTAKE IMPROVEMENTS**  
**CONTRACT C – WATER PLANT ADDITION**

Addendum No. 1 to the plans and specifications for the City of Bridgman, Water System Improvements Project as prepared by Wightman & Associates, Inc. dated September, 2010.

This Addendum No. 1 supplements and modifies the Contract Documents relating to the above referenced project. This Addendum shall be deemed a part of the Contract Documents, and to the extent that the provisions of the other Contract Documents are in conflict herewith, this Addendum shall control.

- A. At the pre-bid meeting, the CONTRACTORS attending requested that an example be provided of appropriate stainless steel clamps for use as joints on the Water Intake Lateral. The CR1 series type 304 stainless steel clamp as manufactured by Cascade Waterworks Mfg., or equal approved by the ENGINEER, will be acceptable.
  
- B. After the pre-bid meeting, it was requested that any available soils information in the vicinity of the water intake caisson on Weko Beach be provided to the CONTRACTORS. We have not taken any soil borings at or near the water intake for this project. The As-Built drawings of the intake caisson (1959) show clay 2 feet below the water intake lateral elevation. When the north and south laterals were replaced in 2001, no clay was encountered. All three intake laterals are at the same elevation. CONTRACTORS preparing proposals for Contract B shall proceed with assuming granular soils will be encountered.
  
- C. The 12” stainless steel well screen specified under Contract B shall be Type 304.
  
- D. The hollow metal door and frame are to be removed and replaced in kind in the following locations at the Water Filtration Plant:
  - Front Entry Door
  - Chlorine Room Door

It is the responsibility of the CONTRACTOR to verify in field the material and equipment necessary to perform the work and to provide a weather tight seal around each of the doors. For budgetary reasons, the door replacements as outlined above may be removed from Contract C.

- E. The CONTRACTORS for Contract C shall replace proposal sheet P-11 with the attached revised sheet P-11 which includes the changes from this addendum and shall include the attached Revised Sheet in their bid.

The CONTRACTOR hereby acknowledges receipt of this Addendum No. 1 and shall include a signed copy with his bid.

Contractor: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

