

***ADDENDUM NO. 2***

***VILLAGE OF BARODA***

***INDUSTRIAL PARK – PHASE I***

July 19<sup>th</sup>, 2011

Addendum No. 2 to the plans and specifications for the Village of Baroda, Industrial Park – Phase I as prepared by Wightman & Associates, Inc. dated July, 2011.

This Addendum No. 2 supplements and modifies the Contract Documents relating to the above referenced project. This Addendum shall be deemed a part of the Contract Documents, and to the extent that the provisions of the other Contract Documents are in conflict herewith, this Addendum shall control.

- A. The section labeled E. Fire Hydrants on Page PS-18 of the specifications for the item of Water Main and Appurtenances, shall be revised to read as follows:

The fire hydrants shall be Waterous Fire Hydrant with 5" valve opening, O.L., 2-2 ½" national standard hose nozzles, 1-5" O.D. steamer nozzle with 4 threads per inch, 5' trench, 12" extension on riser, and 6" diameter M.J. Inlet. Paint red with 7/8" square pentagon operating nut and nozzle thread conforming to local municipal standards.

All hydrants shall have 6" auxiliary gate valves meeting the specifications for valves and boxes included as part of this item and shall be set at locations designated on the contract drawings. They shall be placed with one (1) cubic yard of crushed stone around the base to provide drainage for the hydrant drip. Retainer glands shall be used on the tee, valve and hydrant to provide a completely restrained installation.

The 6" connecting water main from the auxiliary 6" gate valve to the main shall be paid for under the water main pay items.

Catalog cuts shall be submitted to the Engineer for approval prior to ordering.

The CONTRACTOR hereby acknowledges receipt of this Addendum No. 2 and shall include a signed copy with his bid.

Contractor: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_